



PAVUS, a.s.

Notified Body No. 1391

Prosecká 412/74, 190 00 Praha 9 – Prosek

Authorization No. ÚNMZ/SPR/106/4000/18-7 from 20th November 2018

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1391-CPR-2020/0131

In compliance with the Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product:

Fire damper FDMS and FDMS-VAV

Intended use of the product in the building

Fire dampers are used to maintain fire compartments and protect means of escape in case of fire in heating, ventilation and air conditioning (HVAC) systems in buildings. All fire dampers close automatically in response to raised temperatures indicating fire.

placed on the market under the name or company name or trade mark of producer:

MANDÍK, a.s.

Dobříšská 550, 267 24 Hostomice, Czech Republic, IČO 26718405

and produced in the manufacturing plant:

MANDÍK, a.s.

Dobříšská 550, 267 24 Hostomice, Czech Republic

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 15650:2010

under system 1 for the performance set out in this certificate are applied and that the factory production control carried out by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This Certificate was first issued on 14th February 2019 and remains valid until the harmonised standard, the construction product, the assessment and verification procedures for constancy of performance or the manufacturing conditions in the plant of manufacture are significantly modified or the notified product certification body amends or cancels the certificate.

This Certificate replaces and cancels Certificate of Constancy of Performance No. 1391-CPR-2019/0023 of 14th February 2019 issued by NB 1391.

Prague, 20th August 2020



Jaroslav Dufek
Managing Director PAVUS, a.s.
Notified Body No. 1391

Technical parameters of the assessed product *)

External dimension of the element: min. Ø 100 mm – max. Ø 630 mm
 Construction length: 120 mm - 150 mm
 Starting devices and drives for FDMS: Belimo or Gruner with thermoelectric starting device
 Starting devices and drives for FDMS-VAV: Gruner with VAV controller for air flow control
 Material versions: galvanized sheet metal
 stainless sheet metal
 Leak tightness of the damper according to EN 1751: leakage through blade – class 2
 case leakage – class C


The classification according to EN 13501-3+A1*):
EI 45 (ve i↔o) S
EI 60 (ve ho i↔o) S
EI 90 (ve i↔o) S
E 90 (ve i↔o) S
E 120 (ve ho i↔o) S

Assessed product performance

Essential characteristics	Requirement clauses in EN 15650	Findings	Conformity Assessment
Nominal activation conditions/sensitivity:	4.2.1.2	Comply with EN 15650, 4.2.1.2	conforms
- sensing element load bearing capacity	4.2.1.2.2	Comply with EN 15650, 5.2.5, ISO 10294-4:2001, 4.2	conforms
- sensing element response temperature	4.2.1.2.3	Comply with EN 15650, 5.2.5, ISO 10294-4:2001, 4.2	conforms
Response delay (response time):	4.2.1.3	< 2 min	conforms
- closure time			
Operational reliability:	4.3.1, a)	50 cycles performed prior to test	conforms
- cycling			
Fire resistance			
- integrity	4.1.1, a)	E	conforms
- insulation	4.1.1, b)	EI	conforms
- smoke leakage	4.1.1, c)	ES/EIS	conforms
- mechanical stability (under E)	4.1.1, a)	-	conforms
- maintenance of the cross section (under E)	4.1.1, a)	-	conforms
Durability of response delay:	4.2.1.2.2	Comply with EN 15650, 4.2.1.2	conforms
- sensing element response to temperature and load bearing capacity	4.2.1.2.3		
Durability of operational reliability:	4.3.3.2	10 000+10 000 cycles according to EN 15650, Annex C.3.3	conforms
- open and closing cycle tests			
Other characteristics			
Resistance against corrosion	4.2.2 Annex B	Salt spray exposure test – no corrosion occurred (EN 60068-2-52)	conforms

*) Detailed technical parameters and conditions of the final classification according to EN 13501-3+A1 are stated in the Assessment Report of Performance of the Construction product No. P-1391-CPR-2020/0131 of 20th August 2020.

CE
1391
MANDÍK a.s. Dobříšská 550, 267 24 Hostomice, CZ 20 1391 – CPR - 2020/0131
EN 15650 Fire damper type/model: Fire damper FDMS and FDMS-VAV
Classification EI 45 (ve i↔o) S EI 60 (ve ho i↔o) S EI 90 (ve i↔o) S E 90 (ve i↔o) S E 120 (ve ho i↔o) S



(Signature)
Jaroslav Dufek
 Managing Director PAVUS a.s.
 Notified Body No.1391